

O114-11415-2

ADDENDUM NUMBER 1

O'DONNELL PARK
PARKING STRUCTURE FACADE IMPROVEMENTS
Site #784, Bldg. #75
910 East Michigan Street
Milwaukee, WI 53202

Project Number: O114-11415-2

Date of Addendum: March 7, 2011

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated March 1, 2011, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

BIDDING DOCUMENTS

1. Document 00200 Instructions to Bidders:

4.2: CHANGE "Requests for clarifications or interpretations of bidding documents shall be written and received by Architect/Engineer at least 7 days before Bid Due Date." to read: "Requests for clarifications or interpretations of bidding documents shall not be responded to by the Architect/Engineer after 4:00 p.m., Monday, March 7, 2011."

5.2: CHANGE the first sentence from "No substitutions will be considered before receipt of Bids unless Architect/Engineer receives written request for approval at least 7 days before date for receipt of Bids." to read "Requests for Substitutions will not be considered before receipt of the Bids after 4:00 p.m., Monday, March 7, 2011."

2. DRAWINGS

G000 COVER SHEET: CHANGE the listing of A400 series and S400 drawings as follows:

| <u>Current Listing</u> | | <u>Revised Listing</u> | |
|------------------------|-----------------------|------------------------|--------------------------------------|
| A401 | Details | A400 | Details |
| A401-Alt | Add Alternate Details | A400-Alt | Add Alternate Details |
| A402 | Details | A401 | Details |
| A402-Alt | Add Alternate Details | A402-Alt | Add Alternate Details |
| A403 | Details | A403-Alt | Add Alternate Details |
| A403-Alt | Add Alternate Details | | |
| S402 | Details and Sections | S402 | General Notes, Add Alternate Details |

G001 GENERAL NOTES: ADD the following general note:

"Live load limits of 100 pounds per square foot applies to all parking structure plaza levels. Live load limits of 50 pounds per square foot applies to the parking structure parking deck levels."

S122 WISCONSIN AVENUE LEVEL PLAN – SECTOR 2:

REVISE the plaza parapet layout to include lookouts between Column Lines 29-30 and 33-35, and add light pole bases at Columns Lines 30 and 33, per the attached revised partial plan drawing.

S123 WISCONSIN AVENUE LEVEL PLAN – SECTOR 3:



DELETE Sheet Note 1: "No work in this area" and ADD Sheet Notes 1 through 3 and the Legend as shown on Sheet S122.

ADD the plaza parapet 8" concrete wall extension to the south wall approximately between Column Lines C and D.5, and on both sides of the existing bridge (approximately A.9 to B.1 and B.6 to B.8), with associated reference section cuts 6/S401) per the attached revised partial plan drawing.

S401 SECTIONS AND DETAILS: CHANGE the barrier strand details 8 and 9 per the attached revised details.

S402 GENERAL NOTES, ADD ALT. DETAILS: CHANGE the Foundation Detail – Alt. (1) per the attached revised details.

End of Addendum No. 1



WISCONSIN AVENUE LEVEL
PLAN - SECTOR 2

ADDENDUM 1

S-122
 BUILDING NO.: 75
 SITE NO.: 784
 PROJECT: W0114-11415
 DATE: 03/01/2011
 REVISIONS: 03/07/11 ADD #

MILWAUKEE COUNTY DEPARTMENT OF
 TRANSPORTATION AND PUBLIC WORKS
 CITY CAMPUS 2711 W. WELLS ST. - 2ND FLOOR MILWAUKEE, WI 53208



Department of Parks, Recreation and Culture
O'Donnell Park: Parking Structure Facade Improvements
 910 East Michigan Street, Milwaukee, Wisconsin 53202-5607

